From: Analytica AB, Maskinvägen 2, 183 25 Täby. Tfn: 08/52 77 52 00. Fax: 08/768 3423. Email: taby@analytica.se

To: Husarö Tomtägarförening Ref: Anders Harder

Program: DRVTN

Ordernumber: T0706733

Report created: 2007-07-04 by anna-karin.revell

ELEMENT	SAMPLE	S	F	G	Gränvärden
Ca	mg/l	35,3	30,6	51,1	100
Mg	mg/l	4,91	6,21	5,9	30
Na	mg/l	111	102	92,4	100 (200)
K	mg/l	2,48	5,57	3,2	12
Fe	mg/l	0,13	0,0439	0,0386	0,5
Al	µg/l	13,2	25,5	6,28	100
Cu	µg/l	118	8,44	4,13	2000
Mn	µg/l	58	130	61	300
totalhårdhet	°dH	6,08	5,72	8,52	5-10 Medelhårt
lukt vid 20°C		SVAG	ING	ING	-
lukt, art vid 20°C		OBESTŽ	-------	-------	-
turbiditet	FNU	0,7	0,45	0,3	3
färg	mgPt/l	40	30	15	30
konduktivitet	mS/m	76,3	73	78,5	70
pH		8,2	7,9	8,2	6.5-9
alkalinitet	mg HCO3/l	240	250	230	-
nitrit	mg/l	<0.01	<0.01	<0.01	0,1
CODMn	mg/l	8,7	8	4,2	8
ammonium	mg/l	0,18	0,51	0,17	1,5
fosfat	mg/l	<0.10	<0.10	<0.10	0,6
nitrat	mg/l	<0.50	<0.50	0,93	20
fluorid	mg/l	1,5	1,5	<0.15	1,3
klorid	mg/l	76	108	16	300
sulfat	mg/l	32	28	55	250

Please note: This report is preliminary and does not contain all relevant information.
For the definitive and complete reporting of the results, reference is made to the
corresponding written and signed report from Analytica.